



Wels, March 09<sup>th</sup> 2018

## **DC CURRENT FRONIUS ECO 25.0-3-S – 27.0-3-S**

**Fronius International GmbH**

hereby certifies that the inverters

**/ Fronius Eco 25.0-3-S – 27.0-3-S**

do inject a DC current of  $< 0,5 \%$  of the nominal output current into the grid.

**Fronius International GmbH**

Business Unit Solar Energy

Froniusplatz 1

A-4600 Wels

A handwritten signature in blue ink, appearing to read "Martin Heidl".

DI Dr. Martin Heidl  
Head of Systems Technology