

Wels, November 4<sup>th</sup> 2014

## **OVERVOLTAGE PROTECTION FOR FRONIUS SYMO 10.0-3-M – 20.0-3-M**

### **Fronius International GmbH**

hereby confirms that the inverters

- / **Fronius Symo 10.0-3-M – 20.0-3-M**
- / **Fronius Eco**


were tested with the following overvoltage devices:

- / **CITEL DS50PVS-1000G/51**
- / **DEHN DG M YPV SCI 1000 FM**
- / **DEHN DG M YPV SCI 1200 FM**
- / **PHOENIX VAL-MS 1000DC-PV/2+V -FM – 2800627**

Provided that the installation and cabling of the overvoltage protection devices is done as described in the installation- and operation manual of the inverter, the manufacturer's warranty will not be voided.

### **Fronius International GmbH**

Division Solar Energy  
Froniusplatz 1  
A-4600 Wels



Ing. Prok. Martin Hackl  
Head of Division Solar Energy